



Inspection  
Assistance Technique  
Formation professionnelle  
Ressources Humaines  
Sécurité  
Qualité  
Environnement  
Bâtiment en génie civil  
Equipements industriels  
Maîtrise de l'Energie  
Contrôles non destructifs  
Essais et Mesures  
Réception des Installations  
Laboratoires  
Métrologie

**Région FLANDRES HAINAUT**

51 av. de l'Architecte Cordonnier  
BP 247  
59019 LILLE CEDEX  
Tél. 03 20 42 76 42  
Fax. 03 20 40 20 26

**Région PAS de CALAIS SOMME**

ZI - Rue de la Croix de Pierre  
BP 1328  
80013 AMIENS CEDEX  
Tél. 03 22 54 73 80  
Fax. 03 22 52 39 43

**Région AISNE & OISE**

ZAC de Mercières  
BP 537  
60205 COMPIEGNE CEDEX  
Tél. 03 44 30 55 00  
Fax. 03 44 86 60 45

**Région SEINE ESTUAIRE**

2 rue des Mouettes - BP 98  
76132 MONT ST AIGNAN CEDEX  
Tél. 02 35 52 60 60  
Fax. 02 35 52 61 61

**Région SUD NORMANDIE**

Le Citis  
5, Rue d'Atalante  
BP 200  
14209 HEROUVILLE ST CLAIR  
Tél. 02 31 53 31 31  
Fax. 02 31 53 09 79

**Région MAINE BRETAGNE**

Avenue de la Croix Verte  
BP 15325  
35653 LE RHEU CEDEX  
Tél. 02 99 14 71 60  
Fax. 02 99 14 84 94

**Région BRETAGNE OUEST**

ZAC de Kergaradec  
37, Avenue du Baron Lacrosse  
BP 166  
29803 BREST CEDEX 9  
Tél. 02 98 42 14 44  
Fax. 02 98 02 55 19

**Région LOIRE ANJOU**

5 rue de la Johardière - BP 289  
44803 ST HERBLAIN CEDEX  
Tél. 02 40 38 80 00  
Fax. 02 40 92 08 52

**Région CENTRE ATLANTIQUE**

27, Rue Victor Grignard  
ZI de la République 2  
BP 1107  
86061 POITIERS CEDEX 9  
Tél. 05 49 62 66 30  
Fax. 05 49 55 32 12

**SIGMAPHI**

**Rue des Frères Montgolfier – ZI du Prat  
56000 VANNES**

**Written by :**  
**D. JOST**

Attention to M. PORHIEL

**V/Réf : B403/6256**

Saint Herblain, le 03/07/14

**N/Réf : 14N126 - 14317672**

**DELIVERY ORDER**

**SUBJECT :** Mechanical calculation report

Nbre	Référence du document	Désignation - Observation
1	14N126 - 14317672	Mechanical calculation report Of piping elements on drawings 317111-JLA- 702-012, 702-013, 702-028 and 702-029 Following ASME VIII division 1

Ingénieur au service "Calculs"

Donatien JOST



Inspection  
 Assistance Technique  
 Formation professionnelle  
 Ressources Humaines  
 Sécurité  
 Qualité  
 Environnement  
 Bâtiment en génie civil  
 Equipements industriels  
 Maîtrise de l'Energie  
 Contrôles non destructifs  
 Essais et Mesures  
 Réception des Installations  
 Laboratoires  
 Métrologie

**Région FLANDRES HAINAUT**

51 av. de l'Architecte Cordonnier  
 BP 247  
 59019 LILLE CEDEX  
 Tél. 03 20 42 76 42  
 Fax. 03 20 40 20 26

**Région PAS de CALAIS SOMME**

ZI - Rue de la Croix de Pierre  
 BP 1328  
 80013 AMIENS CEDEX  
 Tél. 03 22 54 73 80  
 Fax. 03 22 52 39 43

**Région AISNE & OISE**

ZAC de Mercières  
 BP 537  
 60205 COMPIEGNE CEDEX  
 Tél. 03 44 30 55 00  
 Fax. 03 44 86 60 45

**Région SEINE ESTUAIRE**

2 rue des Mouettes - BP 98  
 76132 MONT ST AIGNAN CEDEX  
 Tél. 02 35 52 60 60  
 Fax. 02 35 52 61 61

**Région SUD NORMANDIE**

Le Citis  
 5, Rue d'Atalante  
 BP 200  
 14209 HEROUVILLE ST CLAIR  
 Tél. 02 31 53 31 31  
 Fax. 02 31 53 09 79

**Région MAINE BRETAGNE**

Avenue de la Croix Verte  
 BP 15325  
 35653 LE RHEU CEDEX  
 Tél. 02 99 14 71 60  
 Fax. 02 99 14 84 94

**Région BRETAGNE OUEST**

ZAC de Kergaradec  
 37, Avenue du Baron Lacrosse  
 BP 166  
 29803 BREST CEDEX 9  
 Tél. 02 98 42 14 44  
 Fax. 02 98 02 55 19

**Région LOIRE ANJOU**

5 rue de la Johardière - BP 289  
 44803 ST HERBLAIN CEDEX  
 Tél. 02 40 38 80 00  
 Fax. 02 40 92 08 52

**Région CENTRE ATLANTIQUE**

27, Rue Victor Grignard  
 ZI de la République 2  
 BP 1107  
 86061 POITIERS CEDEX 9  
 Tél. 05 49 62 66 30  
 Fax. 05 49 55 32 12

**SIGMAPHI**

**Rue des Frères Montgolfier – ZI du Prat**

**56000 VANNES**

Attention to M. PORHIEL

**V/Réf : B403/6256**



**N/Réf : 14N126 - 14317672**

**CALCULATION DEPARTMENT**

***CALCULATION REPORT***

***Of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028  
 and 702-029***

***Following ASME VIII division 1***

C					
B					
A	03/07/14	D. JOST		J. P. LUCIANI	
Rév.	Date	Name	Signature	Name	Signature
		Written by		Checked up by	



# SIGMAPHI

Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029

V / Reference :	B403/6256				
N / Reference :	14N126 - 14317672				
Date :	03/07/2014				
Page :	1	Rév.	A		

## REVISION RECORD

REV	DATE	PAGE / PARAGRAPHE CONCERNED	REVISION DECRIPION
A	03/07/14	All	First edition

<i>Pages</i>	<i>Révision Index</i>		
0	A		
à			
6	A		
<b>APPENDIX A</b>			
A0 à A2	A		
<b>APPENDIX B</b>			
B0	A		



# SIGMAPHI

Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029

V / Reference :	B403/6256					
N / Reference :	14N126 - 14317672					
Date :	03/07/2014					
Page :	2	Rév.	A			

## TABLE OF CONTENTS

1. OBJECT	3
2. REFERENCES	3
2.1. Drawings	3
2.2. Codes standards used	3
2.3. Calculation software	3
3. DESIGN SPECIFICATION	4
3.1. Calculation conditions	4
3.2. Piping description	5
3.3. Materials and allowable stresses	6
4. RESULTS	6
4.1. Pipes calculation	6
4.2. Fittings calculation	7
5. CONCLUSION	8

APPENDIX A – Drawings

APPENDIX B – Microprotol calculation note



# SIGMAPHI

Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029

V / Reference :	B403/6256					
N / Reference :	14N126 - 14317672					
Date :	03/07/2014					
Page :	3	Rév.	A			

## 1. OBJECT

The goal of this calculation note is to review the mechanical strength under static pressure of piping elements of the anti-radiation screen following the assembly drawing 317111-JLA-702-001 Rév H.

The design is done according to ASME VIII division 1.

## 2. REFERENCES

### 2.1. Drawings

- 317111-JLA-702-001 Rév H (Assembly drawing)
- 317111-JLA-702-012 Rév G (Detail drawing of output circuit)
- 317111-JLA-702-013 Rév F (Detail drawing of input circuit)
- 317111-JLA-702-028 Rév E (Detail drawing of pipe #28)
- 317111-JLA-702-029 Rév F (Detail drawing of pipe #29)

Above listed drawings are jointed in appendix A.

### 2.2. Codes standards used

- ASME VIII division 1
- ASME II Part D (nuance SA312 grade 304L, SA249 grade 304L)
- ASME B16.9

### 2.3. Calculation software

- Microprotol V33.0.6.0 software is used for analytical calculations under static pressure.



# SIGMAPHI

Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029

V / Reference :	B403/6256					
N / Reference :	14N126 - 14317672					
Date :	03/07/2014					
Page :	4	Rév.	A			

## 3. DESIGN SPECIFICATION

### 3.1. Calculation conditions

- Fluid: liquid and/or gaseous nitrogen
  - Calculations with : Density of 1
- Operating temperature: -196°C (77K)
  - Calculations with : Temperature in service condition : 20°C (conservative)
- Operating pressure : Internal pressure of 6 bar and external pressure of 1 bar
  - Calculations with : Internal pressure of 7 bar
- Hydraulic test conditions:
  - Pressure : Internal pressure of 10 bar  
(According to §3.6 of calculation report 14N088 Rev A)
  - Temperature : 20°C
  
- Corrosion allowance : 0 mm
- Welding joint efficiency : 1
- Nominal stress : According to ASME II Part D (see §3.5)
  
- Wind : Not applicable
- Seisme : Not applicable
- Fatigue : Not applicable
- Loads and moments : Not applicable



# SIGMAPHI

Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029

V / Reference :	B403/6256				
N / Reference :	14N126 - 14317672				
Date :	03/07/2014				
Page :	5	Rév.	A		

## 3.2. Piping description

**Piping of output circuit** following drawing 317111-JLA-702-012 Rév G is composed of the following components :

- Straight and bended pipes Ø26,9x3,9 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)
- Straight and bended pipes Ø21,3x3,7 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)
- Long radius elbows Ø26,9x3,9 (schedule 80S) in SA403 grade 304L
- Straight tee Ø26,9x3,9 (schedule 80S) in SA403 grade 304L
- Reducing tees Ø26,9x3,9 / Ø21,3x3,7 (schedule 80S) in SA403 grade 304L
- Concentric reducers Ø26,9x3,9 / Ø21,3x3,7 (schedule 80S) in SA403 grade 304L

**Piping of input circuit** following drawing 317111-JLA-702-013 Rév F is composed of the following components :


- Straight and bended pipes Ø26,9x3,9 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)
- Straight and bended pipes Ø21,3x3,7 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)
- Long radius elbow Ø26,9x3,9 (schedule 80S) in SA403 grade 304L
- Straight tees Ø26,9x3,9 (schedule 80S) in SA403 grade 304L
- Reducing tees Ø26,9x3,9 / Ø21,3x3,7 (schedule 80S) in SA403 grade 304L
- Concentric reducers Ø26,9x3,9 / Ø21,3x3,7 (schedule 80S) in SA403 grade 304L

**Piping #28** following drawing 317111-JLA-702-028 Rév E is composed of the following components :

- Straight and bended pipes Ø26,9x3,9 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)
- Long radius elbow Ø26,9x3,9 (schedule 80S) in SA403 grade 304L

**Piping #29** following drawing 317111-JLA-702-029 Rév F is composed of the following components :

- Straight and bended pipes Ø26,9x3,9 (schedule 80S) in SA312 grade 304L (ou SA249 grade 304L)

	<b>SIGMAPHI</b>  <b>Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029</b>	V / Reference : B403/6256	
		N / Reference : 14N126 - 14317672	
		Date : 03/07/2014	
		Page : 6	Rév. A

- Long radius elbow Ø26,9x3,9 (schedule 80S) in SA403 grade 304L

### 3.3. Materials and allowable stresses

Element	Material	Standard	Température	Units: MPa				
				R <sub>p</sub>	R <sub>m</sub>	σ <sub>R</sub>	f <sub>operating</sub>	f <sub>test</sub>
Seamless pipes Welded pipes Buttwelding fittings (elbows, Reducers, tees) following B16.9	304L (ou 316L)	ASME SA312	20°C	172	483	/	<b>115</b>	<b>155</b>
		ASME SA403	20°C	172	483	/	<b>115</b>	/
	304L (ou 316L)	ASME SA249	20°C	172	483	/	<b>97.8</b>	<b>155</b>
			20°C	172	483	/	<b>97.8</b>	/

Nominal stresses are issued of l'ASME II Part D.

## 4. RESULTS

### 4.1. Pipes calculation

Two sizes of pipes are used on the 4 drawings (following §3.2 "Piping description") :


- Ø26,9x3,9 mm
- Ø21,3x3,7 mm

Elément	Epaisseur nominale (en mm)	Tolérance + corrosion (en mm)	Epaisseur utile (en mm)	Vérification de la conception
Pipes Ø26,9 schedule 80S	3.9	0,6	3,3	OK
Pipes Ø21,3 schedule 80S	3.7	0,6	3,1	OK

Calculations of these 2 sizes of pipes are joined in appendix B.

These pipes are compliant to ASME VIII division 1 for calculation condition described on paragraph 3.1.



	<b>SIGMAPHI</b>  <b>Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029</b>	V / Reference : B403/6256					
		N / Reference : 14N126 - 14317672					
		Date : 03/07/2014					
		Page :	7	Rév.	A		

#### 4.2. Fittings calculation

Factory-made wrought buttwelding fittings according to ASME B16.9 are calculated as for seamless pipes of equivalent material, pipe size and wall thickness.

Long radius elbows, straight and reducing tees and reducers are calculated by the calculation of a tube of same diameter, wall thickness and material.

Tees are also calculated as nozzles following openings rules of ASME VIII division 1 (conservative for a standard fittings purchased following ASME B16.9).

Elément	Epaisseur nominale (en mm)	Tolérance + corrosion (en mm)	Epaisseur utile (en mm)	Vérification de la conception
Fittings ( <i>Long radius elbows, straight and reducing tees and reducers</i> ) Ø26,9 schedule 80S	3.9	0,6	3,3	OK
Fittings ( <i>Long radius elbows, straight and reducing tees and reducers</i> ) Ø21,3 schedule 80S	3.7	0,6	3,1	OK

Calculations of fittings (equivalent tubes calculation) and openings are joined in appendix B.

All fittings described in §3.2 are compliant to ASME VIII division 1 for calculation condition described on paragraph 3.1.



# SIGMAPHI

**Calculation report of piping elements on drawings 317111-JLA-702-012, 702-013, 702-028 and 702-029**

V / Reference :	B403/6256					
N / Reference :	14N126 - 14317672					
Date :	03/07/2014					
Page :	8	Rév.	A			

## 5. CONCLUSION

This calculation report shows that the design of piping elements on drawings 317111-JLA-702-012, 317111-JLA-702-013, 317111-JLA-702-028 and 317111-JLA-702-029 is compliant to ASME VIII division 1 rules for design conditions defined in paragraph §3.1.

Remarks :

- Pipes and fittings shall be purchased with respect of material grades (304L) and standards (ASME B16.9, ...) indicated in paragraphe 3.2.

\* \* \*



# SIGMAPHI

**Calculation of piping elements on drawings  
317111-JLA-702-012, 702-013, 702-028 and  
702-029**

V / Reference :	B403/6256					
N / Reference :	14N126 - 14317672					
Date :	03/07/2014					
Page :	A0	Rév.	A			

## ANNEXE A


### Documents de référence

- Plan,
- Nomenclature,




réduction 1"-3/4" ANSI 80S

AH



S/E #1

IA



S/E #2



ZI du port  
des Forges Monjollier  
F-36000 VANNES  
Tel(33) 02 97 01 08 80 Fax (33)02 97 01 08 81 EMAIL Contact@sigmaphi.fr

**DIPOLE**

**Anti-Radiation screen**

DWG NO:

**317111-JLA-702-001**

Rev:

**H**

Drawing	Name	Date
Checked	M. Delbecq	10/03/2014
Approved		
MATERIAL: <b>Matériau &lt;non spécifié&gt;</b>		
Roughness:		
Tel Gen:		
Supplier:		
Weight: <b>1084.16 Kg</b>		
File name:317111-JLA-702-001		

This drawing may not be used without special license or authorisation express  
(Annex of the 11 March 1987)




A3

SCALE: 1:20





SHEET 2 OF 2

ZONE	REV.	DESCRIPTION	DATE	APPROVE
	D	changed bending angles, radius and added notes	27/06/2012	
	E	changed final height	15/04/2013	
	F	changed pipe-to-pipe welding by standard fitting	12/09/2013	MD
	G	changed exit dimension	10/03/2014	






**NOTE:**

- Content liquid nitrogen at 70°K.
- Design pressure: 6atm absolute from 60°K to 300°K.
- Design and manufacturing according to AMSE BPV.
- All pipes and fittings are schedule 80S



Name		Date
Drawing	M. Delbecq	10/03/2014
Checked		
Approved		
MATERIAL: <b>Inox/Stainless steel 304L</b>		
Treat:		
Roughness:		
Tol Gen	+/-1	
Supplier:		
Weight:	<b>6.68 Kg</b>	
	<b>0.00</b>	
File name: 317111-JLA-702-012		
<b>ANTI-RADIATION SCREEN</b>		
<b>output circuit</b>		
DWG NO.	<b>317111-JLA-702-012</b>	
Rev:	<b>G</b>	

ZONE	REV.	DESCRIPTION	DATE	APPROVE
	D	changed bending radius and added notes	27/06/2012	
	E	changed final height	15/04/2013	
	F	changed pipe-to-pipe welding by standard fittings	12/09/2013	MD



**NOTE:**



- Content liquid nitrogen at 70°K.
- Design pressure: 6atm absolute from 60°K to 300°K.
- Design and manufacturing according to AMSE BPV.
- All pipes and fittings are schedule 80S

Name		Date
Drawing	M. Delbecq	04/03/2014
Checked		
Approved		
MATERIAL: Inox/Stainless steel 304L		
Traité:		
Roughness:		
Tol Gen: +/-1		
Supplier:		
Weight: 8.49 Kg		
0.00		
File name: 317111-JLA-702-013		
DWG NO. <b>317111-JLA-702-013</b>		Rev: <b>F</b>


**SIFMAPHI**  
 ZI du port  
 Rue des Fives-Mongollier  
 F-56000 Vannes  
 Tel(33) 02 97 01 08 80 Fax (33) 02 97 01 08 81 EMAIL Contact@sifmaphi.fr

**ANTI-RADIATION SCREEN**

**input circuit**



for intermediary bending positions see CAD file




DÉTAIL A  
ECHELLE 1 : 1

ZONE	REV.	DESCRIPTION	DATE	APPROUVE
	C	changed Ø and other dimensions	06/07/2012	
	D	changed height	15/04/2013	
	F	added note and cotations	03/03/2014	


<p>ZI du port Rue des Forges-Mongollier F-36000 Vannes</p> <p>Tel:(33) 02 97 01 08 80 Fax: (33)02 97 01 08 81 EMAIL Contact@sifmaphi.fr</p>	Drawing	Name	Date
	Checked	M. Delbecq	04/03/2014
	Approved		
MATERIAL: 304L (X2CrNi18-9)		Tratt:	
Roughness:		Tot Gen ±1	
Supplier:		Weight: 7.21 Kg	
Pipe #28		0.00	
File name:317111-JLA-702-028			
DWG NO. 317111-JLA-702-028		Rev: E	

This drawing may not be used without special license or authorisation express (Annex 11, article 1, 1627)





REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVE
	D	changed height	15/04/2013	
	F	changed thickness	03/03/2014	

 Zi du prof Rue des Forges Monjollier F-36000 Yannes	Drawing	Name	Date
	Checked	M. Delbecq	04/03/2014
	Approved		
MATERIAL: <b>Inox/Stainless steel 304L</b>		Treat:	
Roughness:		Tol Gen: ±1	
Supplier:		Weight: <b>6.17 Kg</b>	
		0.00	
File name: 317111-JLA-702-029			
<b>ANTI-RADIATION SCREEN</b>			
<b>Pipe #29</b>			
DWG NO. <b>317111-JLA-702-029</b>			
Rev: <b>F</b>			



# SIGMAPHI

**Calculation of piping elements on drawings  
317111-JLA-702-012, 702-013, 702-028 and  
702-029**

V / Reference : B403/6256

N / Reference : 14N126 - 14317672

Date : 03/07/2014

Page :	B0	Rév.	A						
--------	----	------	---	--	--	--	--	--	--

## ANNEXE B

Note de calcul détaillée



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

### Element(s) of geometry in internal pressure

#### Cylindrical shell under internal pressure.

ASME VIII DIV.1 2010 - 2011a

$t$ = minimum required thickness	$t_n$ = nominal thickness	$E$ = Joint efficiency
$P$ = internal pressure	$S$ = Allowable stress	$T$ = Temperature
$R$ = Internal Radius	$Ca$ = corrosion + tolerance	$\sigma$ = circular stress
$R_o$ = outside radius	$Tol_{\%}$ = tolerance for pipes	$P_a$ = maximum allowable pressure
$t_{n,min} = (t+Ca)/Tol_{\%}$ shall be $\leq t_n$	$t_u = (t_n \times Tol_{\%}) - Ca$ shall be $\geq t$	$P_h$ = Hydrostatic pressure

UG-27 (c)	$t = P(R+Ca)/(SE-0.6P)$	$\sigma = (P(R+Ca) / t_u + 0.6P) / E$	$P_a = S E t_u / ((R+Ca) + 0.6 t_u)$
Appendix 1-1.(a)(1)	$t = PR_o/(SE+0.4P)$	$\sigma = (PR_o / t_u - 0.4P) / E$	$P_a = S E t_u / (R_o - 0.4 t_u)$


#### Shell (01) : 31.05 (Virole)

SA249TP304L							Welded Tube		Schedule : /		DN : /	
$t_n = 3,900$ mm	$R = 9,55$ mm	$Tol_{\%} = /$		PWHT : No		Radiography : Full						
	$R_o = 13,45$ mm	Cor. = 0 mm		Tol. = 0,6 mm		UG-16(b) = 1,5 mm						
	$P$ (MPa)	$P_h$ (MPa)	$T$ (°C)	$S$ (MPa)	$E$	$t_u$ (mm)	$\sigma$ (MPa)	$P_a$ (MPa)	$t$ (mm)	$t_{n,min}$ (mm)		
Operation	N	0,7	0	20	97,8	1	3,300	2,57	26,61	0,096	0,696	
Horizontal test	X	1,0002	0,0002	20	154,8	1	3,300	3,68	42,11	0,087	0,687	
MAWP (20 °C, Corroded) = 26,61 MPa						MAWP (20 °C, new) = 26,61 MPa						

**Isolated Opening(s)**


Figures for all configurations, from FIG. UG-37.1 And FIG UG-40.

Shell ( $\alpha = 0$ ) or Cone ( $\alpha > 0$ ) : in longitudinal plane.



Cylindrical or conical shell : circumferential plane

Head : in the plane that contains the axis of the nozzle and the longitudinal axis of vessel.



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

**Opening A [ in operation Int.P. ]**
*(Process)*

ASME VIII DIV.1

Nozzle without pad on Shell (No. 1)		Set In
Pressure : $P = 0,7$ MPa	Temperature : $20$ °C	
<b>Shell</b>	Material : SA249TP304L	Allowable stress : $S_v = 97,8$ MPa
Joint efficiency : $1$ $E_1 = 1$	Corrosion + tolerance : $Ca_v = 0,6$ mm	Allowable stress : $S = 97,8$ MPa
Ext. Diameter : $D_o = 26,9$ mm	Nominal thickness : $3,9$ mm	Tolerance for seamless pipe : /
<b>Nozzle</b>	Material : SA249TP304L	Allowable stress : $S_n = 97,8$ MPa
Joint efficiency : $1$	Corrosion + tolerance : $Ca_n = 0,6$ mm	Tolerance for seamless pipe : /
Ext. Diameter : $D_{on} = 26,9$ mm	Nominal thickness : $3,9$ mm	
External Projection : $100$ mm	Internal Projection : $0$ mm	
Inclination : $0^\circ$	Eccentricity : $0$ mm	
<b>Flange</b>	Material : /	Type : /
Rating : /	Height : /	/
<b>Pad</b>	Material : /	Allowable stress : $S_p = /$
Height : /	Width : /	Ext. Diameter : $D_{op} = /$
<b>Weld</b> Outside : $leg_{41} = 4$ mm	outer reinforcement : $leg_{42} = /$	Inside : $leg_{43} = /$

$$fr_1 = \min(1, S_n/S_v) = 1 \quad fr_2 = \min(1, S_n/S_v) = 1 \quad fr_3 = \min(1, \min(S_n, S_p)/S_v) = 1 \quad fr_4 = \min(1, S_p/S_v) = 1$$

**Required thickness of the nozzle neck Appendix 1-1**

$$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,096 \text{ mm} \quad R_{on} = 13,45 \text{ mm} \quad E = 1$$

The nozzle neck thickness is adequate per Appendix 1-1.

**Required thickness of the nozzle neck UG-45**

$$t_a = t_{rn} + Ca_n = 0,7 \text{ mm}; t_{b1} = \max[t_{UG-27}, UG-16(b)] + Ca_v = 2,1 \text{ mm}; t_{b3} = \text{Table UG-45} + Ca_n = 3,72 \text{ mm}$$

$$t_{UG-45} = \max[t_a, \min[t_{b3}, t_{b1}]] = 2,1 \text{ mm}$$

The nozzle neck thickness is adequate per UG-45.

**Dimensions FIG. UG-40**

angle of plane with longitudinal axis : angle of each side / vessel wall :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$\beta$ = deflection angle / normal line	$0^\circ$		
$d$ = diameter of the finished opening	$20,3$ mm		
$R_n$ = radius of the finished opening	$10,15$ mm		
$t_i$ = thickness of internal projection	/		
$t_p$ = width of reinforcing pad	/		
$t_x$ = thickness of selfreinforcing	/		
$L$ = height of selfreinforcing	/	/	
Configuration of the reinforcement :	/	/	
$t_e$ = thickness or height of the reinforcement	$0$ mm	$0$ mm	
$t_n$ = thickness of nozzle	$3,3$ mm	$3,3$ mm	
$h$ = height of the internal projection	$0$ mm	$0$ mm	

**Reinforcement checking UG-37**
*opening A [ in operation Int.P. ]*

Required thicknesses UG-37(a)		
$t_r = 0,096$ mm [ UG-27(c) ]	$t = 3,3$ mm	$E = 1$
$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,096$ mm	$R_{on} = 13,45$ mm	$E = 1$

Limits of reinforcement UG-40 :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
UG-40 (b) : $\max [d, R_n + t_n + t] =$	$20,3$ mm	$20,3$ mm	
UG-40 (c) : $\min [2.5t, 2.5t_n + t_e] =$	$8,25$ mm	$8,25$ mm	

Area required UG-37 (c) :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$
$F$ = Correction factor FIG.UG-37	$1$		
$A = d t_r F + 2 t_n / \cos(\beta) t_r F (1 - fr_1)$	$1,9$ mm <sup>2</sup>		

Lengths and heights of calculation of the areas :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$L_1 = \min [UG-40(b)\text{-Radius, length available}]$	$10,15$ mm	$10,15$ mm	
$L_2 = \min [UG-40(c), height available]$	$8,25$ mm	$8,25$ mm	
$L_3 = \min [h, 2.5t, 2.5t_i] =$	$0$ mm	$0$ mm	
$L_5 = \min [UG-40 (b)\text{-}R_{on}, t_p, length available]$	$0$ mm	$0$ mm	


<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

Area available (mm <sup>2</sup> ) :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$	
$A_1 = L_1 (E_1 t - t_r F) - t_n / \cos(\beta) (E_1 t - t_r F) (1 - f_{r1})$	32,5	32,5		
$A_2 = L_2 (t_n - t_m) f_{r2}$	26,4	26,4		
$A_3 = L_3 t_i f_{r2}$	0	0		
$A_{41} = leg_{41}^2 / 2 f_{r2}$	8	8		
$A_{42} = leg_{42}^2 / 2 f_{r4}$	0	0		
$A_{43} = leg_{43}^2 / 2 f_{r2}$	0	0		
$A_5 = L_5 t_e f_{r4}$	0	0		
$A_1 + A_2 + A_3 + A_{41} + A_{42} + A_{43} + A_5 =$	67	67		
small opening UG-36(c)(3)				

The opening is adequately reinforced per UG-37.

**Weld sizes check UW-16(c).**

*opening A [ in operation Int.P. ]*

	Fig. UW-16.1(d) full penetration weld		
	Minimum throat required		
	$t_{e,outward}$	$\min[1/4 \text{ in.}(6 \text{ mm}); 0.7 \times t_{\min}] = 2,31 \text{ mm}$ $t_{\min} = \min[3/4 \text{ in.}(19 \text{ mm}); t, t_n]$	actual $0.7 \times leg_{41} = 2,8 \text{ mm}$
	$t_{e,inward}$	$\min[1/4 \text{ in.}(6 \text{ mm}); 0.7 \times t_{\min}] = /$ $t_{\min} = \min[3/4 \text{ in.}(19 \text{ mm}); t, t_n]$	$0.7 \times leg_{43} - Ca_n = /$
Weld sizes are adequate			

**Weld loads check UG-41(b).**

Strength calculations for attachments welds are not required for this opening in accordance with UW-15(b).

<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

**Opening A [ in test Int.P. ]**
*(Process)*

ASME VIII DIV.1

Nozzle without pad on Shell (No. 1)		Set In
Pressure : $P = 1,0002$ MPa	Temperature : $20$ °C	
<b>Shell</b>	Material : SA249TP304L	Allowable stress : $S_v = 154,8$ MPa
Joint efficiency : 1 $E_1 = 1$	Corrosion + tolerance : $Ca_v = 0,6$ mm	Allowable stress : $S = 154,8$ MPa
Ext. Diameter : $D_o = 26,9$ mm	Nominal thickness : $3,9$ mm	Tolerance for seamless pipe : /
<b>Nozzle</b>	Material : SA249TP304L	Allowable stress : $S_n = 154,8$ MPa
Joint efficiency : 1	Corrosion + tolerance : $Ca_n = 0,6$ mm	Tolerance for seamless pipe : /
Ext. Diameter : $D_{on} = 26,9$ mm	Nominal thickness : $3,9$ mm	
External Projection : $100$ mm	Internal Projection : $0$ mm	
Inclination : $0^\circ$	Eccentricity : $0$ mm	
<b>Flange</b>	Material : /	Type : /
Rating : /	Height : /	/
<b>Pad</b>	Material : /	Allowable stress : $S_p = /$
Height : /	Width : /	Ext. Diameter : $D_{op} = /$
<b>Weld</b> Outside : $leg_{41} = 4$ mm	outer reinforcement : $leg_{42} = /$	Inside : $leg_{43} = /$

$$fr_1 = \min(1, S_n/S_v) = 1 \quad fr_2 = \min(1, S_n/S_v) = 1 \quad fr_3 = \min(1, \min(S_n, S_p)/S_v) = 1 \quad fr_4 = \min(1, S_p/S_v) = 1$$

**Required thickness of the nozzle neck Appendix 1-1**

$$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,087 \text{ mm} \quad R_{on} = 13,45 \text{ mm} \quad E = 1$$

The nozzle neck thickness is adequate per Appendix 1-1.

**Required thickness of the nozzle neck UG-45**

$$t_a = t_{rn} + Ca_n = 0,69 \text{ mm}; t_{b1} = \max[t_{UG-27}, UG-16(b)] + Ca_v = 2,1 \text{ mm}; t_{b3} = \text{Table UG-45} + Ca_n = 3,72 \text{ mm}$$

$$t_{UG-45} = \max[t_a, \min[t_{b3}, t_{b1}]] = 2,1 \text{ mm}$$

The nozzle neck thickness is adequate per UG-45.

**Dimensions FIG. UG-40**

angle of plane with longitudinal axis : angle of each side / vessel wall :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$\beta$ = deflection angle / normal line	0 °		
$d$ = diameter of the finished opening	20,3 mm		
$R_n$ = radius of the finished opening	10,15 mm		
$t_i$ = thickness of internal projection	/		
$t_p$ = width of reinforcing pad	/		
$t_x$ = thickness of selfreinforcing	/		
$L$ = height of selfreinforcing	/	/	
Configuration of the reinforcement :	/	/	
$t_e$ = thickness or height of the reinforcement	0 mm	0 mm	
$t_n$ = thickness of nozzle	3,3 mm	3,3 mm	
$h$ = height of the internal projection	0 mm	0 mm	

**Reinforcement checking UG-37**
*opening A [ in test Int.P. ]*

Required thicknesses UG-37(a)		
$t_r = 0,087$ mm [ UG-27(c) ]	$t = 3,3$ mm	$E = 1$
$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,087$ mm	$R_{on} = 13,45$ mm	$E = 1$

Limits of reinforcement UG-40 :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
UG-40 (b) : $\max [d, R_n + t_n + t] =$	20,3 mm	20,3 mm	
UG-40 (c) : $\min [2.5t, 2.5t_n + t_e] =$	8,25 mm	8,25 mm	

Area required UG-37 (c) :	Longitudinal plane : $\theta = 0^\circ$	Circumferential plane : $\theta = 90^\circ$
$F$ = Correction factor FIG.UG-37	1	
$A = d t_r F + 2 t_n / \cos(\beta) t_r F (1 - fr_1)$	1,8 mm <sup>2</sup>	

Lengths and heights of calculation of the areas :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$L_1 = \min [UG-40(b)\text{-Radius, length available}]$	10,15 mm	10,15 mm	
$L_2 = \min [UG-40(c), height available]$	8,25 mm	8,25 mm	
$L_3 = \min [h, 2.5t, 2.5t_i] =$	0 mm	0 mm	
$L_5 = \min [UG-40 (b)\text{-}R_{on}, t_p, length available]$	0 mm	0 mm	



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

Area available (mm <sup>2</sup> ) :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
$A_1 = L_1 (E_1 t - t_r F) - t_n / \cos(\beta) (E_1 t - t_r F) (1 - f_{r1})$	32,6	32,6		
$A_2 = L_2 (t_n - t_m) f_{r2}$	26,5	26,5		
$A_3 = L_3 t_i f_{r2}$	0	0		
$A_{41} = leg_{41}^2 / 2 f_{r2}$	8	8		
$A_{42} = leg_{42}^2 / 2 f_{r4}$	0	0		
$A_{43} = leg_{43}^2 / 2 f_{r2}$	0	0		
$A_5 = L_5 t_e f_{r4}$	0	0		
$A_1 + A_2 + A_3 + A_{41} + A_{42} + A_{43} + A_5 =$	67,1	67,1		
	small opening UG-36(c)(3)			

The opening is adequately reinforced per UG-37.

<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN20x3.9	2014-07-03 Revision : Pipes and fittings DN20x3.9.emvd (2014-06-26)
--	---	--

## Summary

### Summary of nozzles [ Location and Dimensions ].

Tag	Location				Dimensions (mm)								Flange		
	Loc. (mm)	Ori. (°)	Inc. (°)	Exc. (mm)	Neck				Reinforcement		Projection	DN	Rating	Typ.	
					Diam.	Thk.	Sch.	DN	Type	(a)					(b)
A	300,0	90,00	0,00	0,00	26,90	3,900	/		/	/	/	100,00	/		/

(a),(b) : Pad = thickness, Width ; Self Reinforcing = Height, over thickness ; Internal Plate = thickness, Height

NB : The external projection and the height of over thickness of a self is measured on axis of the nozzle.

### Summary of nozzles [ Type, Adjacent Openings, Goose and Material ].

Tag	Set-in Set-on	Operati ng	Adjacent openings	Goose		hydrostatic height		Material		
				Radius (mm)	Loc. (mm)	Operating (mm)	Test (mm)	Neck	Pad	Flange
A	in	A	None	/	/	0,00	19,1	SA249TP304L	/	/

Nozzle Type A = Process, H = manhole, E = With Blind Flange, L = Instrument, AP = Boot, XT = transition by head, CA = Shell Inlet, CS = Shell Outlet, TA = Channel Inlet, TS = Tubeside Outlet.

### Summary of nozzles [ Type, Weight and Local Loads ].

Tag	Loc. Shell No.	Operating	Mass		Local Loads					
			Nozzle (kg)	Flange (kg)	Longitudinal Shear Load (daN)	Circumferential Shear Load (daN)	Radial Load (daN)	Longitudinal Moment (daN.m)	Circular Moment (daN.m)	Torsional moment (daN.m)
A	01[01]	A	0,3	0,0	0	0	0	0	0	0

Nozzle Type A = Process, H = manhole, E = With Blind Flange, L = Instrument, AP = Boot, XT = transition by head, CA = Shell Inlet, CS = Shell Outlet, TA = Channel Inlet, TS = Tubeside Outlet.

Flange Weight With blind flange if present.

### Summary of Geometry.

Type Tag	Diameter outside (mm)	Length (mm)	Height / base (mm)	Thickness (mm)	Angle (°)	Mass (kg)	Flanges rating	Specifi c Gravity	Material
01[01]	31.05	26,9	400,0	400,0	3,900	0	0,9	8,00	SA249TP304L

Angle : half angle at apex for a concentric cone ; maximum angle between cone an cylinder for an eccentric cone.  
Material : (N) = normalized  
NB : Italic line indicates an element without pressure..



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

### Element(s) of geometry in internal pressure

#### Cylindrical shell under internal pressure.

ASME VIII DIV.1 2010 - 2011a

$t$ = minimum required thickness	$t_n$ = nominal thickness	$E$ = Joint efficiency	
$P$ = internal pressure	$S$ = Allowable stress	$T$ = Temperature	
$R$ = Internal Radius	$Ca$ = corrosion + tolerance	$\sigma$ = circular stress	
$R_o$ = outside radius	$Tol_{\%}$ = tolerance for pipes	$P_a$ = maximum allowable pressure	
$t_{n,min} = (t+Ca)/Tol_{\%}$ shall be $\leq t_n$	$t_u = (t_n \times Tol_{\%}) - Ca$ shall be $\geq t$	$P_h$ = Hydrostatic pressure	
UG-27 (c)	$t = P(R+Ca)/(SE-0.6P)$	$\sigma = (P(R+Ca) / t_u + 0.6P) / E$	$P_a = S E t_u / ((R+Ca) + 0.6 t_u)$
Appendix 1-1.(a)(1)	$t = PR_o/(SE+0.4P)$	$\sigma = (PR_o / t_u - 0.4P) / E$	$P_a = S E t_u / (R_o - 0.4 t_u)$

#### Shell (01) : 31.05 (Virole)

SA249TP304L							Welded Tube			Schedule : /		DN : /	
$t_n = 3,700$ mm		$R = 6,95$ mm		$Tol_{\%} = /$		PWHT : No		Radiography : Full					
		$R_o = 10,65$ mm		Cor. = 0 mm		Tol. = 0,6 mm		UG-16(b) = 1,5 mm					
	$P$ (MPa)	$P_h$ (MPa)	$T$ (°C)	$S$ (MPa)	$E$	$t_u$ (mm)	$\sigma$ (MPa)	$P_a$ (MPa)	$t$ (mm)	$t_{n,min}$ (mm)			
Operation	N	0,7	0	20	97,8	1	3,100	2,03	33,64	0,076	0,676		
Horizontal test	X	1,0001	0,0001	20	154,8	1	3,100	2,91	53,25	0,069	0,669		
MAWP (20 °C, Corroded) = 33,64 MPa						MAWP (20 °C, new) = 33,64 MPa							



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

**Opening A [ in operation Int.P. ]**

(Process)

ASME VIII DIV.1

Nozzle without pad on Shell (No. 1)		Set In
Pressure : $P = 0,7$ MPa	Temperature : $20$ °C	
<b>Shell</b>	Material : SA249TP304L	Allowable stress : $S_v = 97,8$ MPa
Joint efficiency : $E_1 = 1$	Corrosion + tolerance : $Ca_v = 0,6$ mm	Allowable stress : $S = 97,8$ MPa
Ext. Diameter : $D_o = 21,3$ mm	Nominal thickness : $3,7$ mm	Tolerance for seamless pipe : /
<b>Nozzle</b>	Material : SA249TP304L	Allowable stress : $S_n = 97,8$ MPa
Joint efficiency : $E_1 = 1$	Corrosion + tolerance : $Ca_n = 0,6$ mm	Tolerance for seamless pipe : /
Ext. Diameter : $D_{on} = 21,3$ mm	Nominal thickness : $3,7$ mm	
External Projection : $100$ mm	Internal Projection : $0$ mm	
Inclination : $0^\circ$	Eccentricity : $0$ mm	
<b>Flange</b>	Material : /	Type : /
Rating : /	Height : /	/
<b>Pad</b>	Material : /	Allowable stress : $S_p = /$
Height : /	Width : /	Ext. Diameter : $D_{op} = /$
<b>Weld</b>	Outside : $leg_{41} = 4$ mm	outer reinforcement : $leg_{42} = /$
		Inside : $leg_{43} = /$

$$fr_1 = \min(1, S_n/S_v) = 1 \quad fr_2 = \min(1, S_n/S_v) = 1 \quad fr_3 = \min(1, \min(S_n, S_p)/S_v) = 1 \quad fr_4 = \min(1, S_p/S_v) = 1$$

**Required thickness of the nozzle neck Appendix 1-2**

$$t_{rn} = R_{on} (1 - \exp[P/SE]) = 0,076 \text{ mm} \quad R_{on} = 10,65 \text{ mm} \quad E = 1$$

The nozzle neck thickness is adequate per Appendix 1-2.

**Required thickness of the nozzle neck UG-45**

$$t_a = t_{rn} + Ca_n = 0,68 \text{ mm}; t_{b1} = \max[t_{UG-27}, UG-16(b)] + Ca_v = 2,1 \text{ mm}; t_{b3} = \text{Table UG-45} + Ca_n = 3,56 \text{ mm}$$

$$t_{UG-45} = \max[t_a, \min[t_{b3}, t_{b1}]] = 2,1 \text{ mm}$$

The nozzle neck thickness is adequate per UG-45.

**Dimensions FIG. UG-40**

angle of plane with longitudinal axis : angle of each side / vessel wall :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
$\beta$ = deflection angle / normal line	$0^\circ$			
$d$ = diameter of the finished opening	$15,1 \text{ mm}$			
$R_n$ = radius of the finished opening	$7,55 \text{ mm}$			
$t_i$ = thickness of internal projection	/			
$t_p$ = width of reinforcing pad	/			
$t_x$ = thickness of selfreinforcing	/			
$L$ = height of selfreinforcing	/	/		
Configuration of the reinforcement :	/	/		
$t_e$ = thickness or height of the reinforcement	$0 \text{ mm}$	$0 \text{ mm}$		
$t_n$ = thickness of nozzle	$3,1 \text{ mm}$	$3,1 \text{ mm}$		
$h$ = height of the internal projection	$0 \text{ mm}$	$0 \text{ mm}$		

**Reinforcement checking UG-37**

opening A [ in operation Int.P. ]

Required thicknesses UG-37(a)		
$t_r = 0,076 \text{ mm}$ [ UG-27(c) ]	$t = 3,1 \text{ mm}$	$E = 1$
$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,076 \text{ mm}$	$R_{on} = 10,65 \text{ mm}$	$E = 1$

Limits of reinforcement UG-40 :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
UG-40 (b) : $\max [d, R_n + t_n + t] =$	$15,1 \text{ mm}$	$15,1 \text{ mm}$		
UG-40 (c) : $\min [2.5t, 2.5t_n + t_e] =$	$7,75 \text{ mm}$	$7,75 \text{ mm}$		

Area required UG-37 (c) :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
$F$ = Correction factor FIG.UG-37	$1$			
$A = d t_r F + 2 t_n / \cos(\beta) t_r F (1 - fr_1)$	$1,1 \text{ mm}^2$			

Lengths and heights of calculation of the areas :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
$L_1 = \min [UG-40(b)\text{-Radius, length available}]$	$7,55 \text{ mm}$	$7,55 \text{ mm}$		
$L_2 = \min [UG-40(c), height available]$	$7,75 \text{ mm}$	$7,75 \text{ mm}$		
$L_3 = \min [h, 2.5t, 2.5t_i] =$	$0 \text{ mm}$	$0 \text{ mm}$		
$L_5 = \min [UG-40 (b)\text{-}R_{on}, t_p, length available]$	$0 \text{ mm}$	$0 \text{ mm}$		

<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

Area available (mm <sup>2</sup> ) :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$	
$A_1 = L_1 (E_1 t - t_r F) - t_n / \cos(\beta) (E_1 t - t_r F) (1 - f_{r1})$	22,8	22,8		
$A_2 = L_2 (t_n - t_{rn}) f_{r2}$	23,4	23,4		
$A_3 = L_3 t_i f_{r2}$	0	0		
$A_{41} = leg_{41}^2 / 2 f_{r2}$	8	8		
$A_{42} = leg_{42}^2 / 2 f_{r4}$	0	0		
$A_{43} = leg_{43}^2 / 2 f_{r2}$	0	0		
$A_5 = L_5 t_e f_{r4}$	0	0		
$A_1 + A_2 + A_3 + A_{41} + A_{42} + A_{43} + A_5 =$	54,3	54,3		
small opening UG-36(c)(3)				

The opening is adequately reinforced per UG-37.

**Weld sizes check UW-16(c).**

*opening A [ in operation Int.P. ]*

	Fig. UW-16.1(d) full penetration weld		
	Minimum throat required		
	$t_{e,outward}$	$\min[1/4 \text{ in.}(6 \text{ mm}); 0.7 \times t_{\min}] = 2,17 \text{ mm}$ $t_{\min} = \min[3/4 \text{ in.}(19 \text{ mm}); t, t_n]$	actual $0.7 \times leg_{41} = 2,8 \text{ mm}$
	$t_{e,inward}$	$\min[1/4 \text{ in.}(6 \text{ mm}); 0.7 \times t_{\min}] = /$ $t_{\min} = \min[3/4 \text{ in.}(19 \text{ mm}); t, t_n]$	$0.7 \times leg_{43} - Ca_n = /$
Weld sizes are adequate			

**Weld loads check UG-41(b).**

Strength calculations for attachments welds are not required for this opening in accordance with UW-15(b).

<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

**Opening A [ in test Int.P. ]**
*(Process)*

ASME VIII DIV.1

Nozzle without pad on Shell (No. 1)		Set In
Pressure : $P = 1,0001$ MPa	Temperature : $20$ °C	
<b>Shell</b>	Material : SA249TP304L	Allowable stress : $S_v = 154,8$ MPa
Joint efficiency : $1$ $E_1 = 1$	Corrosion + tolerance : $Ca_v = 0,6$ mm	Allowable stress : $S = 154,8$ MPa
Ext. Diameter : $D_o = 21,3$ mm	Nominal thickness : $3,7$ mm	Tolerance for seamless pipe : /
<b>Nozzle</b>	Material : SA249TP304L	Allowable stress : $S_n = 154,8$ MPa
Joint efficiency : $1$	Corrosion + tolerance : $Ca_n = 0,6$ mm	Tolerance for seamless pipe : /
Ext. Diameter : $D_{on} = 21,3$ mm	Nominal thickness : $3,7$ mm	
External Projection : $100$ mm	Internal Projection : $0$ mm	
Inclination : $0^\circ$	Eccentricity : $0$ mm	
<b>Flange</b>	Material : /	Type : /
Rating : /	Height : /	/
<b>Pad</b>	Material : /	Allowable stress : $S_p = /$
Height : /	Width : /	Ext. Diameter : $D_{op} = /$
<b>Weld</b> Outside : $leg_{41} = 4$ mm	outer reinforcement : $leg_{42} = /$	Inside : $leg_{43} = /$

$$fr_1 = \min(1, S_n/S_v) = 1 \quad fr_2 = \min(1, S_n/S_v) = 1 \quad fr_3 = \min(1, \min(S_n, S_p)/S_v) = 1 \quad fr_4 = \min(1, S_p/S_v) = 1$$

**Required thickness of the nozzle neck Appendix 1-2**

$$t_{rn} = R_{on} (1 - \exp[P/SE]) = 0,069 \text{ mm} \quad R_{on} = 10,65 \text{ mm} \quad E = 1$$

The nozzle neck thickness is adequate per Appendix 1-2.

**Required thickness of the nozzle neck UG-45**

$$t_a = t_{rn} + Ca_n = 0,67 \text{ mm}; t_{b1} = \max[t_{UG-27}, UG-16(b)] + Ca_v = 2,1 \text{ mm}; t_{b3} = \text{Table UG-45} + Ca_n = 3,56 \text{ mm}$$

$$t_{UG-45} = \max[t_a, \min[t_{b3}, t_{b1}]] = 2,1 \text{ mm}$$

The nozzle neck thickness is adequate per UG-45.

**Dimensions FIG. UG-40**

angle of plane with longitudinal axis : angle of each side / vessel wall :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$\beta$ = deflection angle / normal line	0 °		
$d$ = diameter of the finished opening	15,1 mm		
$R_n$ = radius of the finished opening	7,55 mm		
$t_i$ = thickness of internal projection	/		
$t_p$ = width of reinforcing pad	/		
$t_x$ = thickness of selfreinforcing	/		
$L$ = height of selfreinforcing	/	/	
Configuration of the reinforcement :	/	/	
$t_e$ = thickness or height of the reinforcement	0 mm	0 mm	
$t_n$ = thickness of nozzle	3,1 mm	3,1 mm	
$h$ = height of the internal projection	0 mm	0 mm	

**Reinforcement checking UG-37**
*opening A [ in test Int.P. ]*

Required thicknesses UG-37(a)		
$t_r = 0,069$ mm [ UG-27(c) ]	$t = 3,1$ mm	$E = 1$
$t_{rn} = P R_{on} / (S_n E + 0.4P) = 0,069$ mm	$R_{on} = 10,65$ mm	$E = 1$

Limits of reinforcement UG-40 :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
UG-40 (b) : $\max [d, R_n + t_n + t] =$	15,1 mm	15,1 mm	
UG-40 (c) : $\min [2.5t, 2.5t_n + t_e] =$	7,75 mm	7,75 mm	

Area required UG-37 (c) :	Longitudinal plane : $\theta = 0^\circ$	Circumferential plane : $\theta = 90^\circ$
$F$ = Correction factor FIG.UG-37	1	
$A = d t_r F + 2 t_n / \cos(\beta) t_r F (1 - fr_1)$	1 mm <sup>2</sup>	

Lengths and heights of calculation of the areas :	Longitudinal plane : $\theta = 0^\circ$ $\delta = 90^\circ$ $\delta = 90^\circ$		Circumferential plane : $\theta = 90^\circ$ $\delta = /$ $\delta = /$
$L_1 = \min [UG-40(b)\text{-Radius, length available}]$	7,55 mm	7,55 mm	
$L_2 = \min [UG-40(c), \text{height available}]$	7,75 mm	7,75 mm	
$L_3 = \min [h, 2.5t, 2.5t_i] =$	0 mm	0 mm	
$L_5 = \min [UG-40 (b)\text{-}R_{on}, t_p, \text{length available}]$	0 mm	0 mm	



<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

Area available (mm <sup>2</sup> ) :	Longitudinal plane : $\theta = 0^\circ$		Circumferential plane : $\theta = 90^\circ$	
	$\delta = 90^\circ$	$\delta = 90^\circ$	$\delta = /$	$\delta = /$
$A_1 = L_1 (E_1 t - t_r F) - t_n / \cos(\beta) (E_1 t - t_r F) (1 - f_{r1})$	22,9	22,9		
$A_2 = L_2 (t_n - t_m) f_{r2}$	23,5	23,5		
$A_3 = L_3 t_i f_{r2}$	0	0		
$A_{41} = leg_{41}^2 / 2 f_{r2}$	8	8		
$A_{42} = leg_{42}^2 / 2 f_{r4}$	0	0		
$A_{43} = leg_{43}^2 / 2 f_{r2}$	0	0		
$A_5 = L_5 t_e f_{r4}$	0	0		
$A_1 + A_2 + A_3 + A_{41} + A_{42} + A_{43} + A_5 =$	54,4	54,4		
	small opening UG-36(c)(3)			

The opening is adequately reinforced per UG-37.

<b>CETE APAVE Nord-Ouest</b> 5, rue de la Johardière 44803 St Herblain CEDEX	<b>Design Calculations</b> Pipes and fittings DN15x3.7	2014-07-03 Revision : Pipes and fittings DN15x3.7.emvd (2014-06-26)
--	---	--

## Summary

### Summary of nozzles [ Location and Dimensions ].

Tag	Location				Dimensions (mm)								Flange		
	Loc. (mm)	Ori. (°)	Inc. (°)	Exc. (mm)	Neck				Reinforcement		Projection	DN	Rating	Typ.	
					Diam.	Thk.	Sch.	DN	Type	(a)					(b)
A	300,0	90,00	0,00	0,00	21,30	3,700	/		/	/	/	100,00	/	/	/

(a),(b) : Pad = thickness, Width ; Self Reinforcing = Height, over thickness ; Internal Plate = thickness, Height

NB : The external projection and the height of over thickness of a self is measured on axis of the nozzle.

### Summary of nozzles [ Type, Adjacent Openings, Goose and Material ].

Tag	Set-in Set-on	Operati ng	Adjacent openings	Goose		hydrostatic height		Material		
				Radius (mm)	Loc. (mm)	Operating (mm)	Test (mm)	Neck	Pad	Flange
A	in	A	None	/	/	0,00	13,9	SA249TP304L	/	/

Nozzle Type A = Process, H = manhole, E = With Blind Flange, L = Instrument, AP = Boot, XT = transition by head, CA = Shell Inlet, CS = Shell Outlet, TA = Channel Inlet, TS = Tubeside Outlet.

### Summary of nozzles [ Type, Weight and Local Loads ].

Tag	Loc. Shell No.	Operating	Mass		Local Loads					
			Nozzle (kg)	Flange (kg)	Longitudinal Shear Load (daN)	Circumferential Shear Load (daN)	Radial Load (daN)	Longitudinal Moment (daN.m)	Circular Moment (daN.m)	Torsional moment (daN.m)
A	01[01]	A	0,2	0,0	0	0	0	0	0	0

Nozzle Type A = Process, H = manhole, E = With Blind Flange, L = Instrument, AP = Boot, XT = transition by head, CA = Shell Inlet, CS = Shell Outlet, TA = Channel Inlet, TS = Tubeside Outlet.

Flange Weight With blind flange if present.

### Summary of Geometry.

Type Tag	Diameter outside (mm)	Length (mm)	Height / base (mm)	Thickness (mm)	Angle (°)	Mass (kg)	Flanges rating	Specifi c Gravity	Material
01[01]	31.05	21,3	400,0	400,0	3,700	0	0,7	8,00	SA249TP304L

Angle : half angle at apex for a concentric cone ; maximum angle between cone an cylinder for an eccentric cone.  
Material : (N) = normalized  
NB : Italic line indicates an element without pressure..