



# Radiation Levels Generated in the Hall and in the Environment during the HKS Experiment

Pavel Degtiarenko

Radiation Physics Group

RadCon/ESH, November 2024

# ERR Charge #6

- Are the radiation levels expected to be generated in the hall acceptable?
- Is any local shielding required to minimize the effects of radiation in the equipment?

# Role of RadCon

- Our work is to make JLab compliant with CFR Title 10 Part 835 – Occupational Radiation Protection
- Includes radiation protection of Life and Environment
- Important part of the job is evaluation of new projects at Jlab, optimizing designs for ALARA purposes, making sure they would satisfy the design criteria and JLab policies
- Protection of Equipment is not a direct RadCon responsibility, but our tools can be used for that goal in collaboration with the Experiment's Subject Matter Experts
- Synergy between the RadCon and other departments, ALARA process helps everyone

# Law Requirements: Design and Control

- § 835.1001: maintain radiation exposure in controlled areas *ALARA* through *engineered* and *administrative* controls
- § 835.1002 sets objectives for facility design and modifications
  - use **optimization methods** to achieve ALARA goals in developing and modification of *facility design* and *physical controls*
  - design objective for controlling personnel exposure: **keep the dose accumulation ALARA**, below 10 mSv (1 rem) in a 2000-hour work year for radiological workers
  - **avoid releases of airborne radioactive material** to the workplace atmosphere under normal conditions
  - Include in the design, and in material selection, features that **facilitate operations, maintenance, decontamination, and decommissioning**
- § 835.1003: maintain *occupational dose* to general employees within limits and ALARA

# Environmental Design Goals

- Practical *criteria* based on design goals in routine beam operations
  - Yearly accumulated dose to the public beyond the JLab Accelerator fence should be **below 10 mrem**
  - Extremely conservative, but it is a good neighbor policy: the dose increase is **less than 10%** of natural radiation background in our area
- Every upcoming experiment's contribution to the environmental dose is evaluated in the process of "**Radiation Budgeting**"
  - During the design stage, its contribution to the dose accumulation at the boundary is calculated and summed for all experiments to be run during a calendar year
  - If the sum exceeds **10 mrem (the "Budget")** then the experiments contributing the most of the dose are recommended for detailed review

# Overview of the Radiation Budgeting


- **Realistic shielding calculations** – conservative design approach using **ALARA Design Goals** as defined in the RadCon Manual
- **Overall confidence** in shielding calculations for typical setups
  - In electromagnetic processes: as needed (**typical accuracy 5 - 10%**)
  - In photo- and electronuclear reactions: **factor 1.5-2.0** due to lack of experimental data and difficulties in the model development
  - The situation is improving as we have the opportunity to use both **FLUKA** and **GEANT** Monte Carlo codes for independent verification.
- **Optimizing shielding design** by finding ALARA solutions for new experimental setups; minimizing dose accumulation in the environment; helping experimentalists to minimize the detector backgrounds and minimize material activation
- **Monitoring radiation environment**, verifying calculations and making adjustments if necessary. “Balancing yearly budget”

# Radiation Budget Calculation Tools

- JLab standard analytical calculation tool **ELEC5** was developed by Geoffrey Stapleton in late 1990s and then converted to the **Excel Rad. Budget** spreadsheet workbook
- Every experiment is split into “Setups”, each setup characterized by the unique combination of beam energy + current, target material + thickness, beamline parameters, and planned beam time
- Standard Hall A or Hall C geometries assumed, no magnetic fields in the beam line (a “typical” experiment)
- Excel Rad. Budget calculations typically give good “1<sup>st</sup>-Order ” values
- More complex experiments with non-standard beam lines and the presence of magnetic fields may require detailed MC simulations

# Radiation Budget for HKS: Beam Line

Ref: P. Medeiros





# ELEC5 Radiation Budget for HKS

Setup #9

Hall: C			<u>RADIATION BUDGET FORM</u>								page: 1 of 1		
Exp. # HKS Group			rev:		run dates: 2026-2027				name of liaison: T. Gogami				
setup number			1	2	3	4	5	6	7	8	9		
beam	energy	GeV	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	totals:	
	current	uA(CW)	2.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	25.0	
exp't target	element		C	Li	Be	B	C	Al	Ca40	Ca48	Pb		
	thickness	mg/cm2	386	100	100	100	150	150	150	150	150		
	dist. to pivot	m	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	Z		6	3	4	5	6	13	20	20	82		
	A		12	7	9	11	12	27	40	48	207		
add'l target 1	element		H										
	thickness	mg/cm2	64										
	dist. to pivot	m	0.0										
	Z		1	0	0	0	0	0	0	0	0		
	A		1	0	0	0	0	0	0	0	0		
critical window	radius	cm	2.85	2.85	2.85	2.85	2.85	2.85	2.85	2.85	2.85		
	dist. to pivot	m	3.24	3.24	3.24	3.24	3.24	3.24	3.24	3.24	3.24		
scattering weighting factor			0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50		
time	run time (100% eff.)	hours	144	120	384	72	168	672	456	552	1000	3568	
		days	6.0	5.0	16.0	3.0	7.0	28.0	19.0	23.0	41.7	148.7	
	installation time	hours										0	
		days	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
dose rate at the fence post (run time)	method 1	urem/hr	0.06	0.24	0.27	0.29	0.50	0.72	0.98	0.84	1.23		
	method 2	urem/hr											
	conservative	urem/hr	0.06	0.24	0.27	0.29	0.50	0.72	0.98	0.84	1.23		
dose per setup		urem	8	29	103	21	84	482	445	464	1231	2868	
% of annual dose budget		%	0.1	0.3	1.0	0.2	0.8	4.8	4.5	4.6	12.3	28.68	
% of allowed dose for the total time												70.41	
% of allowed dose for the run time only												70.41	
<i>If &gt; 200%, discuss result with Physics Research EH&amp;S officer</i>													

2.2 GeV, 25 mA

Pb Target  
150 mg/cm<sup>2</sup>

BL Opening  
R = 2.85 cm at  
Z = 3.24 m

1000 PAC hours  
(48 days)

1.23 μrem/h at  
RBM-4

12% of 10 mrem

**Total 29%**


date form issued: November 15, 2024 authors: P. Degtiarenko




# Sum of Stray Fields with Front Fe beam line shielding

HyperNuclear Stray Field - With PCS Correctors, 1x Fe Beam Pipe and NPS correction magnet

Ref: S. Lassiter




# FLUKA Model for the HKS BL in Hall C




# FLUKA Model for the HKS BL in Hall C

- Realistic Model of the Hall enclosure, including roof and the surrounding space
- Simple model for the Target and the Beam Line as a cone with the opening angle the same as in ELEC5 calculations
- Option to estimate effects of the stray magnetic fields in the beam line
- A first step to the full HKS beam line simulation that would need real geometry
- Allowed to compare with the ELEC5 results for the dose rates at the boundary, evaluate prompt radiation fields in the Hall at the 1<sup>st</sup> order, and evaluate beam line activation
- No model for the beam dump tunnel and beam dump body

# Prompt Dose Rates During Setup #9





# Prompt Dose Rates During Setup #9




# Boundary Dose Rates During HKS Setup #9

A factor of  $\sim 2$  increase when the stray fields are taken into account

Dose rates along Z in 2 m thick, 4 m wide air layer above ground in the vicinity of Hall C



# Activation in the Hall 1 hour after stop





# ERR Charge #6

- Are the radiation levels expected to be generated in the hall acceptable?
  - First preliminary evaluations tell Yes, however the final beam line design still needs to be evaluated
- Is any local shielding required to minimize the effects of radiation in the equipment?
  - The answer is also Yes. It will be dependent on the final design of the beam line and detailed calculations taking into account stray magnetic fields.
  - Damage to electronics and materials in the Hall need to be evaluated by the Experiment
- Dose rate accumulation at the CEBAF boundary is expected to be reasonable for 2-yr operations, and could be optimized