

Experimental Readiness Review for E12-06-105/E12-10-008



Nadia Fomin
June 8th, 2017





THE UNIVERSITY OF
TENNESSEE
KNOXVILLE

Charge elements to be addressed

- 1 – beamline configuration
- 2b – target ladder, EHS&Q
- 3 – manpower and responsibilities
- 4 – beam commissioning procedures and machine protection system
- 5 - Radiation

Hall C Beamline - Layout




Upstream Beamline for EMC/ $x > 1$

(charge element 1)

- EMC/ $x > 1$ uses only unpolarized beam, Compton and Møller polarimeters not required
 - Møller quads used as part of nominal beamline optics
- All magnets required for beam delivery have been used and checked out as part of KPP run
- Key diagnostics required
 - BCMs (current normalization)
 - BPMs
 - Superharps (BPM calibration and beam energy measurement)
- All diagnostics are already functional and operation/precision will be thoroughly verified as part of Fall 2017 run
- *No new beamline components or procedures are required – standard Hall C 12 GeV beamline will be used*
- **Ownership: Upstream Beamline owned/controlled by Ops and Engineering**
 - Detailed responsibilities for beamline elements are enumerated in a document maintained by /Physics/Ops/Engineering: https://hallcweb.jlab.org/experiments/ERR/Beamline_Responsibilities-3.xlsx

Downstream Beampipe




- $x > 1$ requires minimum SHMS angle of 8 degrees
- Will use “medium” beam pipe which allows HMS angle down to 10.5 degrees and SHMS angle down to ~ 7.5 degrees (checked May 23, 2017)
- **Downstream beampipe (up to beamdump entrance) owned by Hall C**

SHMS Beam steering

No problems expected due to SHMS beam steering

- Minimum angle of 8 degrees, expected deflection at beam dump will be less than +/- 4 cm (modeled)
- Dump steering model will be verified as part of Fall 2017 commissioning
- Effect for EMC/x>1 settings will be directly checked downstream of target as part of beam setup procedure





Beam commissioning procedures/responsibilities

(charge items #3 and #4)

- Operation will setup beam using standard hall beam delivery procedure (http://opsntsrv.acc.jlab.org/ops_docs/online_document_files/MCC_online_files/HallC_beam_delivery_proc.pdf)
- Physics (Hall C) will:
 - Check raster functionality
 - Check BCM functionality
 - calibrate BPMs with superharps
- Machine protection system
 - standard beam loss monitors and ion chambers (in the dump tunnel, along the beamline) as in 2017 experiments

Detectors

- Standard Hall C spectrometers to be used
- **HMS configuration**
 - Tracking: 2 drift chambers (6 planes each)
 - Trigger/TOF: 4 plastic scintillator planes
 - Particle ID: Gas Čerenkov and lead glass calorimeter
 - Aerogel Čerenkov NOT necessary (slides out of detector stack easily)
- **SHMS configuration**
 - Tracking: 12 drift chamber planes
 - Trigger/TOF: 3 segmented scintillator planes + 1 segmented Quartz plane
 - Particle ID: Noble Gas Čerenkov, Heavy Gas Čerenkov, and lead glass calorimeter
 - Aerogel Čerenkov NOT necessary



Configuration of Čerenkov detectors



• SHMS

- Require robust pion rejection over a large momentum range (1.4 GeV/c – 11 GeV/c)
- Use both Čerenkov detectors
- 0.5 atm of CO₂ in the heavy gas Čerenkov (pion rejection for low-medium momentum range)
- Neon in Noble Gas Čerenkov provides pion rejection 6-11 GeV/c

• HMS


- Highest momentum setting of 4.6 GeV/c
- 0.5 atm of C₄F₁₀ gas.
- 6 GeV data analysis shows sufficient pion rejection when combined with calorimeter cut

EMC: pi/e ratio




- Lowest momentum settings require pion rejection upto 300:1


SHMS Heavy Gas Čerenkov pion rejection




(a) CO₂ @ $P = 0.50\text{atm}$ & $p = 1.5\text{GeV}/c$



(b) CO₂ @ $P = 0.50\text{atm}$ & $p = 3\text{GeV}/c$




(c) CO₂ @ $P = 0.50\text{atm}$ & $p = 5\text{GeV}/c$



(d) CO₂ @ $P = 0.50\text{atm}$ & $p = 7\text{GeV}/c$

SHMS Noble Gas Čerenkov – neon gas





To reject pions upto 11 GeV/c, a mixture of primarily Neon is required

Experiment Commissioning Procedures

- Repeat checkout procedure used for F2p/F2d
- New calibration needed for Čerenkov due to altered pressure
- Possible update of TOF and Calorimeter calibrations
- Hydrogen elastic running

Target Choice motivated by physics impact




Scans across n/p, A, large range of masses and densities


Targets – Charge item 2b

- 21 physics targets
 - 4 cryogenic targets of “stretched tuna can” design
 - H, ^2H , ^3He , ^4He
 - ^{48}Ca requires housing for oxidation protection
 - Natural calcium eliminates the need for oxidation protection
 - Reduced foil size allows for 23 physics targets + 1 optics
 - Target group is coordinating with industrial hygiene to confirm proper handling of solid target materials
 - Cryogenic target system covered under Target Group procedure and pressure vessel code
 - Max currents to be finalized with heat transfer calculations by Dave Meekins (earlier estimates used in Runplan)

Targets – Charge item 2b



- 2 cryogenic loops
 - H, ^2H
 - ^3He , ^4He
- 3rd loop contains ^{48}Ca (natural calcium in place of ^{40}Ca)
- Dummy target
- Materials to be procured by Hall C/Physics (see D. Meekins' talk for details)



Loop design in progress (D. Meekins)

Radiation Budget

charge item #5

Hall: C			RADIATION BUDGET FORM						page: 2 of 2
Exp. # e-A group		rev: 0	run dates: 2019			name of liaison: Dave Gaskell			
E12-06-105, E12-10-008									
setup number			18	19	20	21	22	23	
beam	energy	GeV	11.0	11.0	11.0	11.0	11.0	11.0	
	current	uA(CW)	60.0	60.0	35.0	60.0	60.0	40.0	
exp't target	element		Cu	Ag	Sn	Au	Th	Al	
	thickness	mg/cm2	772	538	529	388	364	1100	
	dist. to pivot	m	0.0	0.0	0.0	0.0	0.0	0.0	
	Z		29	47	50	79	90	13	
	A		64	60	70	200	142	27	
add'l target 1	element								
	thickness	mg/cm2							
	dist. to pivot	m							
	Z		0	0	0	0	0	0	
	A		0	0	0	0	0	0	
cryo tgt window	element								
	thickness	mg/cm2							
	dist. to pivot	m							
	Z		0	0	0	0	0	0	
	A		0	0	0	0	0	0	
critical window	radius	cm	3.9	3.9	3.9	3.9	3.9	3.9	
	dist. to pivot	m	5.57	5.57	5.57	5.57	5.57	5.57	
scattering weighting factor			0.50	0.50	0.50	0.50	0.50	0.50	
time	run time	hours	151.2	5.04	8.88	23.52	8	76.8	
	(100% eff.)	days	6.3	0.2	0.4	1.0	0.3	3.2	
	installation	hours							
	time	days	0.0	0.0	0.0	0.0	0.0	0.0	
dose rate at the fence post (run time)	method 1	urem/hr	5.45	6.96	3.86	3.91	5.82	3.96	
	method 2	urem/hr							
	conservative	urem/hr	5.45	6.96	3.86	3.91	5.82	3.96	
dose per setup		urem	824	35	34	92	47	304	
% of annual dose budget		%	8.2	0.4	0.3	0.9	0.5	3.0	
% of allowed dose for the total time								255.66	
% of allowed dose for the run time only								255.66	
<i>If > 200%, discuss result with Physics Research EH&S officer</i>									

date form issued:

May 23, 2017

authors: P. Degtiarenko

Backups